

Timber Lakes Water Special Service District

190 North Main\PO BOX 579

Heber City, Utah 84032

435-654-0125

435-654-4925

2012

Annual Drinking Water Quality \ Report Timber Lakes Water SSD

This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve and protect our water resources. We are committed to ensuring the quality of your water. Our ground water sources are springs. They are Lone Pine 1, 2, 3,4,5,6, Cove East and West, and Look Out Mountain. The District is looking into the development of more sources to meet future demand.

Timber Lakes Water SSD has a Drinking Water Source Protection Plan that is available for your review. This plan was updated in 2012. It contains information about source protection zones, potential contamination sources, and management strategies to protect our drinking water. It has been determined that we have a low susceptible level to potential sources of contamination, such as septic tanks, roads, homes etc. This low susceptibility is due in part to the remote locations of our sources and the fact that there are no known potential contamination sources in the protection zones. We have also developed management strategies to provide more protection from possible sources of contamination. If you have any questions regarding source protection, contact our office to review our source protection plan.

In 2012, connections to the water distribution system exceeded 817. When connections are properly installed and maintained, the concerns for cross contamination between the customers' home and the water system are minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water.

The State of Utah requires that Cross Connections be prevented in all culinary water systems. A cross connection is created when any pipe, hose tank or other feature is connected to the water system that provides a pathway for water or materials to be pulled back into the water system. Such conditions could exist during normal operations, during a fire emergency, or during pipeline repair. Under these conditions, where water

2012

[pressures drop in our distribution system, water](#) and or chemicals originating on your private property [can be “sucked”](#) ~~are thus allowed to mingle~~ into the main [lineswater supply system, are thus allowing contaminated water to enter into the main water supply system if not-if not](#) properly protected. This not only compromises the water quality but can also affect the health of all users tied to the system. However, if a cross connection occurs at your home or cabin, it will most likely affect you and your family first.

What can you do? Do not make connection at your home or cabin without discussing the intent and design with TLWSSD personnel. Cross Connections can be created by even simple means including an unprotected garden hose lying in the puddle next to the driveway, or an unprotected lawn sprinkler system that pulls in fertilized or sprayed chemicals. Remember that within Timber Lakes, outside watering is not allowed due to the nature of our water rights, which is sufficient for indoor use only. If you would like to learn more about helping to protect the quality of our water, call us for further information.

We are pleased to report that our drinking water meets Federal and State requirements. If you have any questions about this report please contact Jody Defa at 435-654-0125 or John Schiess with Horrocks Engineering at 801-763-5100. We want our valued customers to be informed about their water utility. If you want to learn more, our monthly meetings are held on the third Tuesday of each month at 6:00 P.M. at the Wasatch County building at 25 North Main in Heber City, Utah.

Timber Lakes Water routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2012. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

In the following table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Microbiological Contaminants:

Total Coliform. Coliforms are bacteria that are naturally present in the environment, and are used as an indicator that other potentially-harmful, bacteria may be present.

Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

Turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates “May” seem out of date.

Waivers (W) - Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples; these waivers are also tied to Drinking Water Source Protection Plans.

Radioactive Contaminants:

Alpha emitters. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Beta emitters. Certain minerals are radioactive and may emit a form of radiation known as beta radiation. Some people who drink water containing beta emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Combined Radium 226/228. Some people who drink water-containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

Inorganic Contaminants:

Antimony. Some people who drink water-containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.

Arsenic. Some people who drink water containing arsenic in excess of the MCL over

many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Asbestos. Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.

Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Beryllium. Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.

Cadmium. Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.

Carbon, Total Organic (TOC). Carbon, Total Organic (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection by products. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Chromium. Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.

Cyanide. Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.

Fluoride. Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Timber Lakes Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Mercury (inorganic). Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.

Nitrate. Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Nitrite. Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Selenium. Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.

Sodium. Sodium is an essential nutrient. However, some people who drink water containing sodium in excess of the MCL may experience health problems.

Sulfate. High levels of sulfates in the drinking water may cause some people to have stomach problems.

Thallium. Some people who drink water-containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

TDS (Total Dissolved Solids). TDS is an aesthetic water quality problem, however high levels may cause some people to experience health problems.

Synthetic organic contaminants including pesticides and herbicides:

2, 4-D. Some people who drink water containing the weed killer 2, 4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.

2, 4, 5-TP (Silvex). Some people who drink water containing Silvex in excess of the MCL over many years could experience liver problems.

Acrylamide. Some people who drink water containing high levels of acrylamide over a long period could have problems with their nervous system or blood, and may have an increased risk of getting cancer.

Alachlor. Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.

Atrazine. Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.

Benzo (a) pyrene [PAH]. Some people who drink water containing Benzo (a) pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.

Carbofuran. Some people who drink water containing Carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.

Chlordane. Some people who drink water containing chlordane in excess of the MCL

over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

Deleon. Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.

Di (2-ethylhexyl) adipate. Some people who drink water containing di (2-ethylhexyl) adipate well in excess of the MCL over many years could experience general toxic effects such as weight loss, liver enlargement, or possible reproductive difficulties.

Di (2-ethylhexyl) phthalate. Some people who drink water containing di (2-ethylhexyl) phthalate well in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.

Dibromochloropropane (DBCP). Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Dinoseb. Some people who drink water containing Dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

Dioxin (2, 3, 7, 8-TCDD). Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Diquat. Some people who drink water containing Diquat in excess of the MCL over many years could get cataracts.

Endothall. Some people who drink water containing Endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

Endrin. Some people who drink water containing Endrin in excess of the MCL over many years could experience liver problems.

Epichlorohydrin. Some people who drink water containing high levels of Epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Ethylene dibromide. Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.

Glyphosate. Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.

Heptachlor. Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.

Heptachlor epoxide. Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

Hexachlorobenzene. Some people who drink water containing Hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.

Hexachlorocyclopentadiene. Some people who drink water containing

Hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.

Lindane. Some people who drink water containing Lindane in excess of the MCL over many years could experience problems with their kidneys or liver.

Methoxychlor. Some people who drink water containing Methoxychlor in excess of the MCL over many years could experience reproductive difficulties.

Oxamyl [Vydate]. Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.

PCBs [Polychlorinated biphenyls]. Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive, or nervous system difficulties, and may have an increased risk of getting cancer.

Pentachlorophenol. Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.

Picloram. Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.

Simazine. Some people who drink water containing Simazine in excess of the MCL over many years could experience problems with their blood.

Toxaphene. Some people who drink water containing Toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

Volatile Organic Contaminants:

Benzene. Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.

Carbon Tetrachloride. Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

Chlorobenzene. Some people who drink water containing Chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.

o-Dichlorobenzene. Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

p-Dichlorobenzene. Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.

1, 2-Dichloroethane. Some people who drink water containing 1, 2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.

1, 1-Dichloroethylene. Some people who drink water containing 1, 1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

cis-1,2-Dichloroethylene. Some people who drink water containing cis-1, 2-dichloroethylene in excess of the MCL over many years could experience problems with

their liver.

trans-1, 2-Dichloroethylene. Some people who drink water containing trans-1, 2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.

Dichloromethane. Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

1, 2-Dichloropropane. Some people who drink water containing 1, 2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Ethylbenzene. Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

Styrene. Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.

Tetrachloroethylene. Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.

1, 2, 4-Trichlorobenzene. Some people who drink water containing 1, 2, 4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.

1, 1, 1-Trichloroethane. Some people who drink water containing 1, 1, 1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.

1, 1, 2-Trichloroethane. Some people who drink water containing 1, 1, 2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.

Trichloroethylene. Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Toluene. Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.

Vinyl Chloride. Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

Xylenes. Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.

Annual Drinking Water Quality/Report | 2012

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	0	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2012	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	0	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2012	Human and animal fecal waste
Turbidity for Ground Water	N	0	NTU	N/A	5	2008	Soil runoff
Inorganic Contaminants							
Antimony	N	ND	ppb	6	6	2011	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic	.N	.0005	ppb	0	10	2011	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	.043-.101	ppb	2000	2000	2011	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium	N	ND	ppb	4	4	2011	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium	N	ND	ppb	5	5	2011	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium	N	ND	ppb	100	100	2011	Discharge from steel and pulp mills; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a.0.254-0.278 c.0	ppb	1300	AL=1300	2012	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	ND	ppb	200	200	2011	Discharge from steel/metal factories; discharge from plastic and fertilizer factories

Annual Drinking Water Quality/Report | 2012

Fluoride	N	ND	ppb	4000	4000	2011	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. .0005 - .0015 b.0	ppb	0	AL=15	2012	Corrosion of household plumbing systems, erosion of natural deposits
Mercury (inorganic)	N	ND	ppb	2	2	2011	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nickel	N	ND	Ppb	10000	10000	2011	
Nitrate (as Nitrogen)	N	a. .4 -.5	ppb	10000	10000	2012	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen)	N	.33-.48	ppb	1000	1000	2008	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	ND	ppb	50	50	2011	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	3.9-4.9	ppm	None set by EPA	None set by EPA	2011	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	2-3	ppm	1000*	1000*	2011	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
*If the sulfate level of a public water system is greater than 500 ppm, the supplier must satisfactorily demonstrate that: a) no better water is available, and b) the water shall not be available for human consumption from commercial establishments. In no case shall water having a level above 1000 ppm be used.							
TDS (Total Dissolved solids)	N	124-154	ppm	2000**	2000**	2011	Erosion of natural deposits
**If TDS is greater than 1000 ppm, the supplier shall demonstrate to the Utah Drinking Water Board that no better water is available. The Board shall not allow the use of an inferior source of water if a better source is available.							
Thallium	N	ND	ppb	1	2	2011	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Disinfection By-products							
TTHM [Total trihalomethanes]	ND	10	ppb	0	80	2011	By-product of drinking water disinfection
Haloacetic Acids	ND	9.2	ppb	0	60	2011	By-product of drinking water disinfection
Chlorine	ND	0-.5	ppm	4	4	2012	Water additive used to control microbes

Annual Drinking Water Quality/Report | 2012

Radioactive Contaminants							
Alpha emitters	N	1.7	pCi/l	0	15	2011	Erosion of natural deposits
Combined Radium 228/226	N	1.5-2.6	pCi/l	0	5	2011	Erosion of natural deposits
Synthetic Organic Contaminants including Pesticides and Herbicides (If Water System has been issued waivers for these samples then this table can be deleted from the report).							
2,4-D	N	ND	ppb	70	70	2011	Runoff from herbicide used on row crops
2,4,5-TP (Silvex)	N	ND	ppb	50	50	2011	Residue of banned herbicide
Alachlor	N	ND	ppb	0	2	2011	Runoff from herbicide used on row crops
Atrazine	N	ND	ppb	3	3	2011	Runoff from herbicide used on row crops
Benzo(a)pyrene (PAH)	N	ND	ppt	0	200	2011	Leaching from linings of water storage tanks and distribution lines
Carbofuran	N	ND	ppb	40	40	2011	Leaching of soil fumigant used on rice and alfalfa
Chlordane	N	ND	ppb	0	2	2011	Residue of banned termiticide
Dibromochloropropane	N	ND	ppt	0	200	2011	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb	N	ND	ppb	7	7	2011	Runoff from herbicide used on soybeans and vegetables
Endrin	N	ND	ppb	2	2	2011	Residue of banned insecticide
Heptachlor	N	ND	ppt	0	400	2011	Residue of banned termiticide
Heptachlor epoxide	N	ND	ppt	0	200	2011	Breakdown of heptachlor
Hexachlorocyclopentadiene	N	ND	ppb	50	50	2011	Discharge from chemical factories
Lindane	N	ND	ppt	200	200	2011	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor	N	ND	ppb	40	40	2011	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
PCBs [Polychlorinated biphenyls]	N	ND	ppt	0	500	2011	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol	N	ND	ppb	0	1	2011	Discharge from wood preserving factories
Picloram	N	ND	ppb	500	500	2011	Herbicide runoff
Simazine	N	ND	ppb	4	4	2011	Herbicide runoff
Volatile Organic Contaminants							
Benzene	N	ND	ppb	0	5	2011	Discharge from factories; leaching from gas storage tanks and landfills

Annual Drinking Water Quality/Report | 2012

Carbon tetrachloride	N	ND	ppb	0	5	2011	Discharge from chemical plants and other industrial activities
Chlorobenzene	N	ND	ppb	100	100	2011	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene	N	ND	ppb	600	600	2011	Discharge from industrial chemical factories
p-Dichlorobenzene	N	ND	ppb	75	75	2011	Discharge from industrial chemical factories
1,2 - Dichloroethane	N	ND	ppb	0	5	2011	Discharge from industrial chemical factories
1,1 - Dichloroethylene	N	ND	ppb	7	7	2011	Discharge from industrial chemical factories
trans - 1,2 - Dichloroethylene	N	ND	ppb	100	100	2011	Discharge from industrial chemical factories
1,2-Dichloropropane	N	ND	ppb	0	5	2011	Discharge from industrial chemical factories
Ethylbenzene	N	ND	ppb	700	700	2011	Discharge from petroleum refineries
Styrene	N	ND	ppb	100	100	2011	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene	N	ND	ppb	0	5	2011	Discharge from factories and dry cleaners.
1,2,4 -Trichlorobenzene	N	ND	ppb	70	70	2011	Discharge from textile-finishing factories
1,1,1 - Trichloroethane	N	ND	ppb	200	200	2011	Discharge from metal degreasing sites and other factories
1,1,2 -Trichloroethane	N	ND	ppb	3	5	2011	Discharge from industrial chemical factories
Toluene	N	ND	ppb	1000	1000	2011	Discharge from petroleum factories
Vinyl Chloride	N	ND	ppb	0	2	2011	Leaching from PVC piping; discharge from plastics factories
Xylenes	N	ND	ppb	10000	10000	2011	Discharge from petroleum factories; discharge from chemical factories

As you can see by the table, our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water **IS SAFE** at these levels.

In addition to the sampling outlined above, we have also sampled for (31 Synthetic Organic Contaminants, Radiological Contaminants, and 1 Unregulated Contaminant including Pesticides). These additional chemicals were not detected.

All Sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water including bottled water, may reasonably expect to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water for their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791).

MCLs or Maximum Contaminant Levels are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.